



Department of General Services CAPITAL PROJECTS MANAGEMENT DIVISION

ADDENDUM 2

Juvenile Detention Facility Security System Upgrades Project 740 Beck Avenue, Fairfield, CA 94533

November 13, 2019

This Addendum shall be considered part of the bid documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated into those documents. Where provisions of the following supplementary data differ from those of the original bid documents, this addendum shall govern and take precedence.

Bidders are notified that they shall make any necessary adjustment(s) in their estimate on account of this addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified in this addendum.

The clarification and/or additions and/or deletions that are described in this addendum shall be included in the specifications and/or drawings.

This ADDENDUM supersedes the original PROJECT MANUAL and DRAWINGS dated October 17, 2019 to the extent that it contradicts them; all other conditions remain unchanged.

Acknowledgement of receipt of this ADDENDUM is required on the bid form.

REQUEST FOR INFORMATION

1. On the job walk we noted that there were existing lighting controls panels in the housing units. Facility personnel indicated that the lighting controls buttons did not go through the PLC, but connected directly to an existing low voltage lighting control panel. There is no mention of including lighting control in the new touch screen controls. Is lighting control required?
Lighting control shall be integrated with touch screen controls. Provide manufacturer required PLC's, physical wiring, and programming from touch screen control to lighting control panel(s). Touch screen functionality shall match existing pushbutton system.
2. The specification states that we are to use Veracity Professional Services for installation of Genetec software updates and licenses, for configuration and programming of new servers, and for migration of stored video data. What is the contact information of



Department of General Services

CAPITAL PROJECTS MANAGEMENT DIVISION

Veracity? Are they familiar with this Project and do they have a defined scope of work already?

Veracity contact information; sales@veracityglobal.com. Veracity has a copy of the detailed scope as outlined in Specification Section 283000 Para. 1.3,B, 2, a-f. They will be preparing a cost for this scope of work for distribution to potential Bidders.

3. System server is specified to be BCD model server. Will an HP Gen10 server meeting the same specifications be an acceptable substitute?

The HP Gen10 is not an acceptable alternate. The BCD specified server is a Dell based OEM chassis specifically utilized to maintain the County standard Dell technology infrastructure. An alternate Dell server or Dell OEM server chassis of equal specification shall be acceptable, but will require the full five year onsite next business day warranty covering 100% of all parts and labor (excluding hard drives). Additionally, all service calls shall be provided by a Dell certified technician.

4. CML Security is an elite level partner with Genetec. We propose to only use our staff and our vendors for the procurement, installation and configuration of the Digital Video Management System hardware and software as described in this Section. Is this acceptable?

The scope of work detailed in Section 283000- Para.1.3,B,2 a-f will require completion by Veracity Professional Services as specified. All other DVMS work scope may be performed by in house staff or vendors as required.